

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD

CENTRAL VALLEY REGION

TENTATIVE ORDER R5-2020-XXXX

RESCINDING WASTE DISCHARGE REQUIREMENTS ORDER 95-121

The California Regional Water Quality Control Board, Central Valley Region (Central Valley Water Board), finds that the Central Valley Water Board adopted the following Order which is no longer applicable for the reasons shown:

- a) Waste Discharge Requirements Order 95-121, adopted on 26 May 1995, prescribes requirements for the discharge from Carriage Auto Wash's wastewater treatment and disposal system, Butte County (Facility). The Facility is comprised of four 1,500 gallon sedimentation tanks. The third tank periodically diverts water to the water recycling system. Water not diverted continues to the fourth tank and is discharged to one of two leachfields. Recycled water is pumped to a 1,200 gallon collection tank where it is treated with an aluminum sulfate coagulant and chlorine bleach, and then reused in the car wash. The Facility was damaged in the 2018 Camp Fire. Since then the Facility has not been operable and there are no plans to reopen the Facility. Therefore, it is appropriate to rescind Waste Discharge Requirements Order 95-121.

IT IS HEREBY ORDERED that the above Waste Discharge Requirements Order 95-121 is rescinded.

I, Patrick Pulupa, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the Central Valley Water Board on <DD MONTH> 2020.

---

PATRICK PULUPA, Executive Officer